



MEMORANDUM

Date: July 29, 1982

To: Mike Duvall, SLRO, Rick Roberts, PBRO & Burt McCullough, SRO

From: PM Paul Meiburger, WMP

THROUGH: Art Groner, WMP *AG*

Subject: Safety-Kleen Inspection Report

Please amend your inspection report for Safety-Kleen to include the requirement in 10 CSR 25-7.050(2)(A)4. cross-referenced to 10 CSR 25-7.050(4)(A)3. which requires underground tanks to have some type of leak detection system installed. The way we will handle this is that in the cover letter we will ask them to propose to us what type of leak detection system they plan to use and then the regional office and the central office will review their proposal and then discuss over the phone whether to approve or disapprove the proposal. If you have any questions or comments, please call.

PM/bki

RECEIVED

AUG 06 1982

SLRO

MDV

MISSOURI DEPARTMENT OF NATURAL RESOURCES
P.O. Box 1368 2010 Missouri Blvd. Jefferson City, Missouri 65102 (314) 751-3241



R00086660

RCRA Records Center

Christopher S. Bond Governor
Fred A. Lafser Director

Division of Environmental Quality
Robert J. Schreiber Jr., P.E. Director